



# Georgia Pollutant Discharge Elimination System

[avick \(logout\)](#)

## Spill

[Find Spill](#)**Spill Begin Date:**

2013-01-03 00:00

**Entry Date:**

2013-01-16 00:00

**Spill End Date:**

2013-01-03 00:00

**Incident Reported Date:**

2013-01-03 00:00

**Call Received By:**

Kelly Kutrufis

**Employee Responsible:**

Kelly Kutrufis

**Spill Entered By:**

Kelly Kutrufis

**Facility Type:**

Pump Station

**Permit Number:**

GA0021521

**River Basin:****Facility Name:**

SAINT SIMONS ISLAND WPCP

**Primary Cause of Overflow:**

Power failure

**District:**

Coastal District

**Overflow Type:**

Raw Sewage

**Waterbody Type:**

Ditch

**Quantity (Gallons):**

10000

**Waterway Impacted:****Fecal Coliform:**

No

**Posting Begin Date:**

2013-01-03

**Monitoring Begin Date:**

2013-01-05

**Number of Days Posted:****Monitoring End Date:**

2013-01-08

**Cause Comment:**

The power failed and the axillary generators started up the resulting power surge that caused the main pump station to go offline and did not automatically reset resulting in the spill.

**Corrective Action:**

Reset the main pump station and a vac-con crew cleaned up site. Signs were posted. Testing was done in the area to ensure no fecal coliform was present.

**Notes:**

They are going to monitor any standing water in the ditch for the next seven days to ensure there is no contamination.

**Overflow Location:****Spill Questions:**

NO Major Spill?

NO Appropriate Fisheries Notified?

NO Outfall Spill?

YES Coastal Agencies Notified?

NO Has the Spill Entered the Waterway?

NO Drinking Water Agencies Notified?

YES Signs Posted?

NO Emergency Personnel Notified?

YES Media Contacted?

NO Border State(s) Notified?

NO Dead Fish Kills Reported?

YES District Environmental Office?

YES Public Notice Underway?

YES Health Department Notified?

NO Water Quality Violation?

NO Downstream Notified?

NO Major Sampling Underway

NO First Month Sample Recorded?

NO Seven-Day Sampling Received?


NO Third Month Sample Recorded?

NO Chattahoochee Notified?

NO Twelfth Month Sample Recorded?

NO Impacted waterway is on 303(d) list?

## Location:



- ☐ Aerial  
☒ Street

- ☐ Facilities  
☐ Outfalls  
☐ Drinking Water Intake Points (secure)  
☐ NHD streams  
☐ 303(d) waterbodies  
☐ Health districts  
☐ Counties

Coordinate(s):

Reference Point:

Radius:

Reference Datum:

Collection Method:

Source Map Scale Number:

County:

Horizontal Accuracy Measure:

Glynn

City:

Saint Simons Island

Edit

Delete

## Violations

| Type | Date | Statute | Comment | Status | Actions |
|------|------|---------|---------|--------|---------|
|------|------|---------|---------|--------|---------|

Add

Documents

Additional Information

Contacts